


28' CONCRETE RURAL SECTION TYPICAL CROSS SECTION

NTS

- NOTES: 1. TRANSVERSE SAWED CONTRACTION JOINT AT 12' INTERVALS FOR CONCRETE PAVEMENT.
- * 2. LIME SHALL BE APPLIED AT 6 % BY WEIGHT MINIMUM QUANTITY IS 36#/SY. IN SOME AREAS A GREATER QUANTITY (OR A LIME SERIES TEST) MAY BE REQUIRED AT THE CITY'S DISCRETION.
3. BAR DITCH SIDE SLOPE VARIES DEPENDING UPON DESIGN. NO GREATER THAN 3:1 WITHOUT AMORING.
- ** 4. CEMENT SHALL BE APPLIED AT 5% BY WEIGHT. MINIMUM QUANTITY IS 36#/SY.

REVISIONS	REVISIONS
	Revised 11/16/99 (Bar Size & Concrete Layer)
 CITY OF ARLINGTON, TEXAS	
PROJECT NUMBER PROJECT NAME (PROJECT LIMITS)	
DATE:	SCALE:
DRAWN BY:	CHECKED BY: